



Cuba Community Fire Protection District

PO Box 511, 600 S Franklin Ave, Cuba, MO 65453
573-885-3366 | 573-885-0256 Fax | www.cubamofire.com

Food

Applicants are to fill out top section. A safety inspection of your business will be conducted. Any violations must be corrected before any business can open. The Cuba Fire Protection District has adopted and follows the 2018 IBC Building and Fire Codes. Permit fees must be paid at the time the application is submitted. Any questions please contact the Fire Marshal.

Date of Application: _____
Physical Address: _____ Business Name: _____
Name: _____ Business Owner Phone: _____ Email: _____
Business Owner Name: _____ Property Owner Phone: _____ Email: _____

Property Owner Name: _____
Cuba City Limits: Yes / No

**** Certificate of occupancy is valid for 1 year and is not bound to a specific address. The permit must be displayed and visible at all times.**

Signature of Owner: _____

Wheel Chocks: _____ Fire Extinguisher: _____ 10' Separation: _____ Generator 5' from Vehicle: _____ Not blocking Fire Lane: _____

Cylinders upright and secured: _____ No Flammable liquids stored inside: _____ Fire Suppression Hood: _____

Approved By: _____ Title: _____ Permit Fee: _____

Date Issued: _____ Permit Number: _____

Check # _____ Date: _____ Received By: _____

FOOD TRUCK REQUIREMENTS

1. An occupancy permit shall be required by the Cuba Fire Protection District. The permit is valid for 1 year and is not bound to a specific address. The permit must be displayed and visible at all times. 319.2
2. Wheel Chocks shall be used to prevent mobile and temporary cooking operations from moving.
3. A Minimum on one 2A:10ABC fire extinguisher shall be provided when a generator or other fuel fire appliance is used, wood or charcoal is used, or electric cooking is performed. 906.4
4. Mobile cooking operations shall be separated from buildings or structures, combustible materials, vehicles, and other cooking operations by a minimum of 10’.
5. Mobile or temporary cooking operations shall not block fire department access roads, fire lanes, hydrants, or other fire protection devices.
6. Portable generators shall be positioned so that the exhaust is at least 5’ in any direction away from any openings, air intakes, means of egress, or part of the building or vehicle.
7. Flammable liquids shall not be stored inside of the temporary cooking areas.
8. Cylinders shall be secured in an upright position. 319.8.2
9. Deep fat fryers or other appliances having combustible liquids heated by LP gas or electricity shall be protected by an approved hood fire suppression system. 319.3- 904.12

Please contact the Fire Marshal with any questions at Cubafpd@gmail.com or 573-885-3366

